

## ***Training for Essex County***

Name:

Date:

### **LDH2: Hydrant with No Steamer Available Performance / Task description**

1. Remove 4-inch supply line from bed of truck.
2. Remove Hydrassist Valve and Hydrant Bag from compartment.
3. Bring proper tools ie... radio, hydrant wrench, two spanners.
4. Wrap hydrant properly by creating an "X" around the backside of the hydrant leaving sufficient amount of hose to make connection.
5. Signal vehicle operator to move forward while standing on hose at the "X".
6. When appropriate unwrap hose.
7. Loosen 2 ½ inch caps then place hydrant wrench on stem.
8. Remove caps and place them at rear of hydrant.
9. Attach two Morse gates to hydrant in the open position.
10. Attach two "short" 3 inch supply lines to Morse gates.
11. Attach 4-inch storz to 4 1/2 in threaded adapter to Hydrassist valve inlet "A" labeled "WATER"
12. Attach Siamese to Hydrassist valve outlet "B" labeled "TO FIRE".
13. Attach the two "short" 3 inch feeder hoses from the Morse gates to the Siamese
14. Attach 4-inch supply line to Hydrassist valve outlet "B" labeled "TO FIRE".
15. Position handle on Hydrassist valve toward out "B" labeled "TO FIRE".
16. Request permission to charge hydrant.
17. Open hydrant fully and correctly.
18. Retrieve tools and rejoin crew; checking couplings along the way.

**Signature of Evaluator** \_\_\_\_\_